

消防處
牌照及審批總區
通風系統課
九龍尖沙嘴康莊道一號
消防局總部大樓五樓



FIRE SERVICES DEPARTMENT
LICENSING & CERTIFICATION COMMAND
Ventilation Division
5/F, Fire Services Headquarters Building,
1 Hong Chong Road, Tsim Sha Tsui East, Kowloon

本處檔號 Our Ref: FP (LC) 316/18
來函檔號 Your Ref: 6011, 6012 & 6013
圖文傳真 Fax: (852) 2382 2495
電話 Tel. No.: (852) 2251 4140

28 February 2007

STAR GLORY Technologies Limited
Room 1702, 17/F.
Workingberg Commercial Building
41-47 Marble Road
North Point
Hong Kong
(Attn. Mr. Paul CHAN)

Dear Sir,

**“Actionair” Re-settable Thermal Release Cassette
Used in “Actionair” Fire Damper**

I refer to your above letters of 31.1.2007, 8.2.12007 and 15.2.2007 regarding the used of “Actionair” re-settable thermal release cassette.

I would like to inform you that we have no in principle objection to the use of “Actionair” re-settable thermal release cassette rated at 69°C with “Actionair” Fire/Shield Series 101, 201, 301 and 401 and Series FB curtain fire dampers in ventilation systems subject to the maintenance of a proper quality assurance system by the manufacturer and the availability of the related records of sample checks for inspection on request.

The cassette shall bear the following product identification marks on its body:

1. Brand name
2. Temperature rating mark of 69°C &
3. Circular dial date showing the month and year of manufacture

This assessment is subject to review in February 2011.

Yours faithfully,

for Director of Fire Services

KFH/
FileCode: star glory actionair cassette 20070228.doc